
NE 3rd St
N/B I-405 Ramp
Sunset Blvd N
Bronson Way N
I-405 FWY
I-405 FWY
S/B I-405 Ramp
Maple Valley Hwy
N/B I-405 Ramp
Monterey Dr NE
Areas of recent 2 breaks in May & June 2015
Temporary capping of 24" main by City Forces on 6/19/15
Install 550-ft of 18" or 20" HDPE inside existing 24" D.I. pipe.
Install 120-ft of 10" HDPE inside 12" C.I. pipe.
Quality Inn
Shari's Restaurant
Area of previous break around 2003
Cedar River Park